

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. School / 027 / 2025-26

Dated: 09/06/25

It is certified that an inspection team headed by Dr. Rajendra Yadav & Team

(Name of Officers with designation) from C.H.C. Badlapur Jp. PHED

inspected the Shri Pujari Maharaj Convent School, Tiya, Badlapur Jp.

(Name & Address of the school) on 09/06/2025 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. WAT/JNP/030/2025-26 dated 05/06/25

of Water Analysis Report Dist. Jp (PHED Lab) certified that

the Shri Pujari Maharaj Convent School (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till One year

Signature with Seal: _____

Name: _____

Designation: _____

Name & Address of the Office / Department: _____

To The Manager

(Name & Address of the Institution)

Shri Pujari Maharaj Convent School

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

Tiya, Badlapur Jp.

अधिसूचना अधिसूचना
खण्ड कार्यालय
उत्तर प्रदेश जल निगम (ग्रामीण)
जौनपुर



Water Analysis Report, District-Jaunpur, UTTAR PRADESH

Rept No	378	Date	05/06/2025	Page No	01
---------	-----	------	------------	---------	----

Customer Details

Office Name and Address	SHREE PUJARI MAHARAJ CONVENT SCHOOL, TIYARA, BADALAPUR, JAUNPUR, U.P.
Ref Letter No.	WAR/JNP/030/2025-26

Basic details of sample

District	JAUNPUR	Tehsil	BADALAPUR
Gram Panchayat	BADALAPUR	Village	TIYARA
Habitation	-	Location	TIYARA, BADALAPUR, JAUNPUR, U.P.
Water Source	R O Water	Sample No.	Sample 5
Quality of Sample	1000ml (Normal)	Date of S.C.	05/06/2025
Receiving Date	05/06/2025	S. Collector	Mr. SANJAY PATHAK
Sample Depositor	MR. SANTOSH KUMAR SINGH		
Analysis Start Date	05/06/2025	Analysis Completion Date	05/06/2025

Technical Data of Analysis

SR	Analyzed parameters (Unit of Measurement)	Observed Value	Specified Values as per BIS		Ref. Method of Analysis
			Acceptable Limit	Permissible Limit	
1	2	3	4	5	6
1	pH	6.45	6.5-8.5	6.5-8.5	IS 3025 (Part 11): 1983:2021(Electrometric Method)
2	Turbidity (NTU)	0.45	1.00	5.00	IS 3025 (Part 10): 1984:2021(Nephelometer Method)
3	TDS. Mg/1	321	500	2000	IS 3025 (Part 16): 1984:2021(Gravimetric Method)
4	Chloride (as Cl), mg/1	11	250	1000	IS 3025 (Part 32): 1988:2021(Titration Method)
5	Total Alkalinity (as Na ₂ CO ₃), mg/1	179	200	600	IS 3025 (Part 23): 1986:2021(Titration Method)
6	Total Hardness (as CaCO ₃), mg/1	94	200	600	IS 3025 (Part 21): 2009:2021(Titration Method)
7	Calcium (as Ca), mg/1	15.9	75	200	IS 3025 (Part 40): 2019
8	Magnesium (as Mg), mg/1	14.6	30	100	IS 3025 (Part 46): 2019
9	Nitrate (as NO ₃), mg/1	4	45	No Relaxation	APHA 23rd Ed 2017, 4500-NO ₃ (B.Ultraviolet Spectrophotometric Screening Method)
10	Fluoride (as F), mg/1	0.358	1.00	1.5	APHA 23rd Ed 2017, 4500-F (C. Ion Selection Electrode Method)
11	Iron (as Fe), mg/1	1.00	1.00	No Relaxation	APHA 23rd Fd 2017, 3500-Fe (B Phenanthroline Method)
12	Residual Chlorine	0.2	NA	0.2	IS 3025 (Part 26): 2021
13	Total Coliform (MPN/100mL)	0	NA	0.0	IS 1622

Note-

1. This Certificate refers only to the particular sample(s) submitted for testing.
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
3. The test result reported in this certificate is valid at the time of and under the stated conditions of measurements.
4. Sample will be stored up to 15 days (in case of non-perishable items only) from the date of issue of tests reports unless otherwise specified.

Prepare by

Lab Technician



Authorized Signatory

Quality/Technical Manager